



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location :- VVS GANDHI CENTENARY SCHOOL CA SITE NO.396/A, 1ST 'N' BLOCK, RAJAJINAGAR BANGALORE-560010			Report date: 30/03/2026		
			Report Number: 0015		
			Reference: TRF		
			Sample code: 0015		
			Date of Sample collection: 26/03/2026		
			Analysis start date: 27/03/2026		
			Analysis completion date: 27/03/2026		
Sample quantity: 1 Liter					
Sample Particulars: Borewell water					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7.3	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, µS/cm @25°C Temp	780	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.4	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	490	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO ₃ , mg/l	203.0	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO ₃ , mg/l	208.2	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	51.3	75	200	IS 3025 (Part-40) : 2024
10	Magnesium as Mg, mg/l	19.4	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	86.1	250	1000	IS 3025 (Part-32) : 2025
12	Sulphate as SO ₄ , mg/l	36.9	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	0.8	1	1.5	APHA 24 th Edition
14	Nitrate as NO ₃ , mg/l	9.6	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2019
Remark: The above given sample conforms to the permissible limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: Megha K.S Senior Analyst/Junior Analyst			Authorized Signatory: Pavithra B.S Technical Manager: Pavithra B.S		



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---